



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 14/11/2025

Area: WT

Equipment	Job
AF 2(O)	Drive control card and Key pad replaced , tested OK
CP 1	Panel and Motor side ppm done
OP 3	D6, motor TB fixing and stator cantactor kit and top unit fixing done
OP 2,3 and 4	After rake,maintenance done