



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 25/10/2025

Area: WT

Equipment	Job
AF 4(O)	Removed motor shifted to tippler house and checked winding values found ok
AF 4(O)	Motor tested with spare drive found Ok
OP 4	After rake maintenance done