



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 27/08/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-32	BC NOT RUNNING	DUE TO JAMMING .... INFORMED OPR	08:30:00	08:45:00	
2	CHP	CC-36 SCR-1	NO DRIVES WORKING	MAIN MCCB TRIPPED ... MADE ON AND TESTED	10:50:00	11:20:00	
3	CHP	CC-39 SCR-7	LT NOT WORKING	PCRD OT... RELEASED	11:20:00	11:30:00	
4	CHP	CC-44	TRIPPED ON OLR	RESET DONE	10:10:00 11:00:00	10:20:00 11:10:00	
5	CHP	CC-27A	STOPPED ON CHUT SENSOR	WIRE LOOSE IN CJB ... BYPASSED	10:15:00	10:40:00	KEPT IN CKT
6	CHP	CC-28	TRIPPED ON OLR	RESET	11:00:00 12:20:00	11:10:00 12:25:00	
7	CHP	CC-114	TRIPPED ON OLR	RESET DONE	11:45:00	11:54:00	
8	CHP	CC-26	STOPPING ON ZSS	CAGE STUCK ... MADE FREE	06:50:00	07:00:00	
9	CHP	CC-40 SCR-3	LT NOT WORKING	DRIVE TRIPPED ... RESET DONE	13:40:00	13:50:00	
10	WT	CC-3 BD	TRIPPED ON OLR	RESET DONE	07:10:00	07:15:00	