



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/07/2025

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 76R ZSS	PROBE DAMAGED	BYPASSED	08:45:00	09:10:00	INFORMED TO B SHIFT
2	OHP	TBS ON CO 22	RIGHT LUFF BREAK ER COIL GOT OPEN	PLACEMENT DONE	06:30:00	07:00:00	COIL REPLACED BY G SHIFT
3	OHP	BRC ON CC 34	ANALOG OUTPUT FUSE BASE LOOSE	PROPERLY FIXED THEN OK	09:30:00	10:00:00	
4	OHP	CO 35	OLR ACTED	RESET	09:05:00	09:10:00	
5	OHP	CO 26	OLR ACTED	RESET	07:50:00	08:00:00	
6	CHP	SCR 7 ON CC 39 SLEW	BREAK FAIL ALARM ACTED	RESET	07:40:00	07:50:00	
7	CHP	SCR 1 ON CC 35 LT	M2 and M5 TRIPPED TRACK JAMMING	RESET	06:55:00	07:15:00	
8	CHP	SCR 5 ON CC 32 B/C	RUNNING SLOW DUE TO OVER LOAD ON CONVEYOR	NO ELEC PROBLEM	07:50:00	08:05:00	
9	CHP	SCR 2 ON CC 34 LT	PCRD O/T ACTED	RELEASED	07:50:00	08:00:00	
10	CHP	SCR 1 ON CC 35	SLEW 30 DEGREE LIMIT NOT COMING	BYPASSED AND INFORMED TO G SHIFT	09:40:00	09:50:00	
11	CHP	SCR 5 ON CC 32	LT M2, M6 TRIPPED	MADE IT ON	10:10:00	10:20:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/07/2025

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC 131	OLR ACTED	RESET	08:45:00 10:50:00 12:20:00	08:50:00 10:55:00 12:25:00	
13	CHP	CC 114	OLR ACTED	RESET	13:30:00	13:35:00	
14	CHP	CC 26A T/T NOT MOVING	MPCB TRIPPED	MADE IT ON	07:15:00	07:25:00	
15	CHP	CC 33	OLR ACTED	RESET	08:55:00	09:05:00	