



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 21/11/2025

Area: WT

Equipment	Job
CP 1	After rake maintenance done
OP2,4,6 and 7	After rake maintenance done
OP 6	5A2, rotor cantactor coil found burnt, replaced it
OP 6	D5 and D6 checked in de clutch found cascade time not rotating (to be rectified)
MIs	13 nos C clamps assembled for pusher
MIS	vacum cantactor (3TF68) repaired and tested ,kept as spare
MIS	spare Brake Panel shifted and kept as spare in LC 9