



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/11/2025

Area: CHP

| Equipment | Job |
|----------------|---|
| CC 44 | Running inspection was done |
| CC 107,126 | Motor vibration readings noted |
| R 1 | Luff down relay replaced and tested |
| SCR 6,9,10 | Hydraulic motors greasing done |
| CC 204,205,206 | Local trail taken after making the conveyor healthy |
| CC 201 to 211 | PPM was done |