



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 12/12/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 21	ZSS NEUTRAL CUT IN CJB	REJOINT	20:50:00	21:00:00	
2	OHP	CO 26	OLR ACTED	RESET	16:50:00	17:00:00	
3	OHP	CO 16 STOPPING	DUE TO T/T CHUTE SENSOR COMMUNICATION BIT MISSING	DELAY WAS INCREASED TO 4S THEN OK	19:00:00	19:20:00	
4	CHP	CC 47	DRIVE TRIPPED	RESET	20:40:00	20:50:00	
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	18:30:00	21:40:00	7 TIMES
6	CHP	CC 54	OLR ACTED	RESET	16:45:00 20:35:00	16:50:00 20:40:00	
7	CHP	CC 58	OLR ACTED	RESET	18:25:00	18:35:00	
8	CHP	S1 ON CC 39	LT POTENTIOMETER	REPLACED	18:40:00	19:00:00	
9	CHP	SCR 6 ON CC 38 LUFF	MPCB TRIP	MADE IT ON	19:10:00	19:25:00	
10	CHP	SCR 6 ON CC 38	LT M2 TRIP TRACK JAMMING	INFORMED TO OPRN	21:00:00	21:10:00	
11	CHP	SCR 6 ON CC 38	LUFF MPCB TRIPPING	TO BE CHECKED	21:45:00	22:00:00	