



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 29/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	Co17/ 23	Chute flap gate olr acted	Reset done	14:30:00	14:40:00	
2	OHP	TBS on CO24	Right boom luffing not working found MCB trip	Made on	14:30:00	14:45:00	
3	OHP	WOBR on CO29	LT not working found material jam	Informed to operation	20:00:00	20:15:00	
4	OHP	CO29	olr acted	Reset done	20:35:00	20:40:00	
5	OHP	CO26	olr acted	Reset done	21:05:00	21:10:00	
6	OHP	WOBR on CO34	CT limit cable damaged changing work by g shift	Clearance given	14:30:00	17:00:00	
7	OHP	RSCO1a	Stopping on ZSS found ZSS cage bolts missing	Fixed with new bolts	18:18:00	18:44:00	
8	CHP	CC 49	not running,zss acted,zss probe wire got cut	probe replaced	16:00:00	16:20:00	
9	CHP	CC 36 SCR1	b/c not running,cjs acted,jamming	informed operation	17:15:00	17:30:00	
10	CHP	CC23 belt	ZSS acting found cable loose	cable reconnected then ok	15:00:00	15:15:00	
11	CHP	CC 40 SCR 3	LT not working,drive trips in OVn fault	reset	20:50:00	21:00:00	
12	CHP	CC54	olr acted 4 times	Reset done	18:15:00	19:00:00	
13	CHP	CC114	olr acted	Reset done	17:05:00	17:15:00	
14	CHP	CC113	olr acted	Reset done	19:25:00	19:35:00	
15	CHP	CC51	MPD olr tripped feeding conveyor stopped	Reset done	21:30:00	21:35:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/08/2025

Shift: B

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	WT	Op10	No communication	Communication changed by spare Avalon modem	17:00:00	17:00:00	No delay