



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/06/2025

Area: IOSA

Equipment	Job
PLC	CHECKED THE HEALTHINESS OF 90-30 CPU IN LC-2 .
BRC	LIGHTING DEFECTS RECTIFIED AND REPLACED DEFECTIVE LIGHT FITTINGS.
BLENDER RECLAIMER	ISOLATED VCU AND ISOLATOR PANEL REMOVED FROM BLENDER.
WOBR-FLS	MAINTENANCE DONE ON SLIPRING AND CHECKED THE TIGHTNESS OF TERMINATION. CHECKED THE FUNCTION OF SPACE HEATER.