



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED	RESET DONE	07:00:00	07:10:00	
2	OHP	TW-6 ON CO-18	TRIPPED ON OLR	RESET DONE	09:40:00	09:50:00	
3	OHP	BRC ON CO32	B/C NOT STOPPING FOUND COMMEND AUX-RELAY STUCK UP	RELAY REPLACED WITH NEW ONE	11:00:00	11:30:00	
4	OHP	CO-30	OLR ACTED	RESET DONE	12:10:00	12:20:00	
5	CHP	CC-26	REPORTED BRS NOT RESETED	SENSOR CLEANING THAN OK	06:55:00	07:10:00	
6	CHP	CC-112 SCR-8	REPORTED B/W NOT RUNNING MPR TRIP DUE TO GROUND FAULT	INFORMED TO G-SHIFT	06:30:00	07:00:00	
7	CHP	CC-32 SCR-5	REPORTED NO POWER FOUND OPERATOR CABIN SIDE E/STOP ACTED	RELEASED THAN OK	06:45:00	06:55:00	
8	CHP	CC-45	OLR ACTED (3TIMES)	RESET DONE	07:10:00 08:35:00 10:50:00	07:15:00 08:40:00 10:55:00	
9	CHP	CC-31	OLR ACTED	RESET DONE	11:45:00	11:55:00	
10	CHP	CC-125	OLR ACTED	RESET DONE	10:30:00	10:35:00	
11	CHP	CC-117	OLR ACTED	RESET DONE	11:30:00	11:40:00	
12	CHP	CC-51	FEEDING CONVEYOR OLR ACTED (2TIMES)	RE4SET DONE	11:15:00 12:40:00	11:20:00 12:45:00	
13	CHP	VF-2	NOT RUNNING FOUND DRIVE CHORD PROBLEM	INFORMED TO G-SHIFT	07:05:00	07:40:00	
14	WT	CC-3 (C/D)	OLR ACTED	RESET DONE	11:30:00	11:40:00	