



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/08/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC-29	Reported tripped	OLR acted.Reset done	11:30:00	11:35:00	
2	CHP	CC-51	Feeding conveyor C-31 stopped	Due to MPD acted for CC-51	12:05:00	12:10:00	
3	CHP	CC-35 SCR-1	Slew not taking place	Right limit acted.(2times).Released and tested okay.	07:10:00 10:05:00	07:20:00 10:15:00	
4	CHP	CC-111 S-3	slew not taking place	Slew area jamming found	06:45:00	06:55:00	Informed to operation .after cleaning done tested okay
5	CHP	CC-34 SCR-2	LT not taking place	LT OT acted(4times).Released and tested okay	09:10:00 09:50:00 10:40:00 11:25:00	09:18:00 10:00:00 10:50:00 11:35:00	
6	CHP	CC-105 SCR-7	Slew not taking place	Spider break fail alarm in spider.Reset done and tested okay	09:25:00	09:35:00	
7	CHP	CC-41	Reported tripped	OLR acted.reset done	11:10:00	11:20:00	
8	CHP	CC-104 SCR-9	LT not moving	PCRD guide stuck.Made free and tested okay	10:50:00	11:00:00	
9	CHP	CC-104 SCR 9	LT not taking place	PCRD control MCB Tripped.Made on and tested okay	12:50:00	13:00:00	