



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 20/05/2025

Area: OHP

Equipment	Job
TIS-6 ON CO-29	bypassed feedbacks at io rack and zss at module as conveyor belt was slipping.