



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/01/2026

Area: CHP

Equipment	Job
CM 19	cleaning work done
CC 41 Chute vibrator	Base welding done and motor fixed.
CC 37 F/G	Motor overhauling done
LC 2 to LC 17	Single strand Profibus cable replaced with multi strand
SCR 1,3	5 nos 30W lamp replaced
CC 105,108,31,33,112,223	Running inspection and vibration done
CC 51,54	PPM was done