



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 12/07/2025

Incharge(s): V Balaji Naik,G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO87	Found RED OLR acted	Reset done then ok	23:20:00	23:30:00	
2	OHP	Stacker on CO20	LBC not running found olr acted	Reset done	00:00:00	00:20:00	
3	OHP	BRC on CO33M	Pump not running found oil level low	Informed to operation and mechanical	00:20:00	00:40:00	
4	OHP	CO37A	Conveyor stopping due to ZSS acting found stone struck in cage	Stone removed then ok	04:40:00	04:50:00	
5	OHP	CO9	complaint received from B shift motor temperature is 89 degrees and bearing temperature is 78 degrees due to rollers missing	Operation requirement checked motor temperature 40 degrees bearing temperature 40 degrees power and control kept on given clearance	22:00:00	04:00:00	
6	CHP	SCR5 on CC32	BC ZSS bypassed as ZSS cage struck from B shift pending job	ZSS cage changed BC bypass removed clearance given	22:20:00	22:40:00	
7	CHP	SCR5 on CC32	BC stopped found ZSS cage nut bolt missing cage damaged	ZSS bypassed and given clearance	23:05:00	23:15:00	
8	CHP	CC125	Tripped on over load on healthy stop 2times	OLR rest done	23:35:00 23:55:00	23:40:00 00:00:00	