



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 27/05/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-4a	stopped on pull cord	hardware contact missing .... bypassed in panel	03:45:00	04:05:00	
2	OHP	TT-4	CABLE JOINT PROBLEM	JOINT DONE AND PLACEMENT DONE ON BPC-1	22:00:00	22:30:00	
3	OHP	CO-11 CD	MPCB TRIPPED	RESET DONE	02:48:00	03:00:00	
4	OHP	BRC ON CO-30	BW-1 OLR ACTED	RESET DONE	00:10:00	00:30:00	
5	OHP	BRC ON CO-30	BC NOT RUNNING	OLR ACTED ... RESET DONE	01:45:00	02:00:00	
6	OHP	CO-34	TRIPPED ON OLR	RESET DONE	01:00:00	01:15:00	
7	OHP	CO-29	TRIPPED ON OLR	RESET DONE	00:50:00	05:20:00	5 TIMES
8	CHP	CC-26 F/G	TRIPPED	MPCB MADE ON	22:20:00	22:30:00	
9	CHP	CC-26	TT LT TRIPPED	MPCB MADE ON	22:30:00	22:40:00	
10	CHP	CC-125	TRIPPED ON OLR	RESET DONE	01:50:00 03:50:00	02:00:00 04:00:00	
11	CHP	SCR-5 CC-32	LT NOT WORKING	EMERGENCY PB ACTED NEAR PCRD	02:40:00	03:20:00	
12	CHP	CC-41	C/S ACTING	BYPASSED IN PROGRAM	01:00:00	01:10:00	
13	CHP	SCR-4 CC-33	SLEW NOT WORKING	OIL LEAKAGE INFORMED TO MECH	03:30:00	03:45:00	