



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/08/2025

Area: WT

Equipment	Job
OP 1	D4 motor removed from bed due to motor coupling loose
OP 2	Panel and motor side ppm done
OP 1 and 5	After rake maintenance done