



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 15/10/2025

Area: CHP

Equipment	Job
LC-18,CM-17,CM-18	Redundant OFC network made healthy
CC-31 T/E	lighting circuit fault rectified and 70w lights arranged for improved lighting
SCR-4	70W lights installed in the machine for lighting
CC-31,SCR-4	ppm work done
SCR-4	old cables removal work done. Boom conveyor ZSS probe fixing done