



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/12/2025

Area: WT

Equipment	Job
OP 1	D4 motor changing alignment and testing done, removed motor shifted
OP 3,4 and 6	After rake maintenance done
CO 2 level	Area lighting cable found cut ,10 mtrs cable laid and connected.