



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 27/06/2025

Area: CHP

Equipment	Job
CC-51 H/E road side hoist	ppm and up limit switch adjustment done and kept in circuit
LC-18	Dewatering Auto circuit probe cable replaced and auto mode checking done
CC-41	Motor CJB to panel cable gallery new control cable laid
SCR-9,SCR-3	New antenna installed
SCR-1	feed table zss module connection done and input bit programming done
Misc	STK-1 and SCR-1 interchanging done