



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 03/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 12 A	brs acted	reset	00:15:00	00:20:00	
2	OHP	BF 5A	stopped in zss,probe alignment disturbed	probe adjusted	04:30:00	04:40:00	
3	OHP	WOBR on co 29	LT not working,M3 olr acted	reset	05:00:00	05:15:00	
4	OHP	CO 34	OLR acted	reset	00:30:00	00:40:00	
5	CHP	cc 51	mpd tripped 20 times	reset	23:20:00	05:30:00	
6	CHP	cc 55	motor tripped on earth fault	reset,and checked	02:20:00	02:40:00	
7	CHP	cc 131	motor tripped 5 times	reset	01:00:00	03:00:00	
8	CHP	rg2	motor tripped	no problem found	03:40:00	03:50:00	
9	CHP	cc 40 scr2	slew not working,coal jamming	informed operation	00:00:00	00:05:00	
10	CHP	CC 223	drive tripped in ol	reset	00:50:00	01:00:00	
11	WT	OT 2	d2 tripped in PGF1 fault 7 times	reset	01:10:00	03:45:00	
12	WT	OT 1	D1 tripped in pgf1 fault	reset	04:45:00 05:30:00	04:50:00 05:35:00	