



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|--------------------|----------------------|----------------------|---------|
| 1 | OHP | co 12 A | brs acted | reset | 00:15:00 | 00:20:00 | |
| 2 | OHP | BF 5A | stopped in zss,probe alignment disturbed | probe adjusted | 04:30:00 | 04:40:00 | |
| 3 | OHP | WOBR on co 29 | LT not working,M3 olr acted | reset | 05:00:00 | 05:15:00 | |
| 4 | OHP | CO 34 | OLR acted | reset | 00:30:00 | 00:40:00 | |
| 5 | CHP | cc 51 | mpd tripped 20 times | reset | 23:20:00 | 05:30:00 | |
| 6 | CHP | cc 55 | motor tripped on earth fault | reset,and checked | 02:20:00 | 02:40:00 | |
| 7 | CHP | cc 131 | motor tripped 5 times | reset | 01:00:00 | 03:00:00 | |
| 8 | CHP | rg2 | motor tripped | no problem found | 03:40:00 | 03:50:00 | |
| 9 | CHP | cc 40 scr2 | slew not working,coal jamming | informed operation | 00:00:00 | 00:05:00 | |
| 10 | CHP | CC 223 | drive tripped in ol | reset | 00:50:00 | 01:00:00 | |
| 11 | WT | OT 2 | d2 tripped in PGF1 fault 7 times | reset | 01:10:00 | 03:45:00 | |
| 12 | WT | OT 1 | D1 tripped in pgf1 fault | reset | 04:45:00 05:30:00 | 04:50:00 05:35:00 | |