



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 24/11/2025

Shift: C

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-14A	Reported BRS acted	Checked and reset done	23:30:00	23:45:00	
2	OHP	CO-33M	Reported tripped	OLR acted.Reset done	22:56:00	23:05:00	
3	OHP	CO-26	Reported tripped	OLR acted.Reset done(2 times)	03:50:00	04:00:00	
4	OHP	CO-33S	Reported not running	Power recycled and tested okay	02:40:00	02:50:00	
5	OHP	BRC on CO-33M	Reported LT not taking place	Wrong complaint	23:40:00	23:50:00	
6	CHP	CC-38 SCR-6	LT not working	M-2 tripped.Reset done	22:28:00	22:40:00	
7	CHP	CC-125	Reported tripped	OLR acted.Reset done	01:56:00 03:40:00	02:03:00 03:48:00	
8	CHP	CC-39 SCR-2	LT not working	PCRD OT acted.Released and tested okay(2times)	02:17:00 03:29:00	02:30:00 03:41:00	
9	CHP	Cc-39 SCR-2	LT not working	Fuse burnt in I/O rack for PCRD command.Replaced and tested okay	04:02:00	04:15:00	
10	CHP	CC-33 SCR-5	LT not working	PCRD OT limit acted.Reset done	04:00:00	04:12:00	
11	CHP	Cc-54	Reported tripped	OLR acted.Reset done(4 times)	00:30:00	05:50:00	
12	CHP	RG-3	FLap gate tripped	OLR acted.Reset done	22:55:00	23:00:00	
13	IOSA	BRC	Reported BW-1 not rotating	B/W stuck.Solenoid pressed released and tested okay	01:30:00	01:45:00	