



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 27/06/2025

Area: WT

Equipment	Job
OP 10	D5 bed slots cutting and motor placement done
OP 10	D1 bed slots cutting,motor placement,alignment and termination done
OP 10	D 2,3 and 5 Motors removed from bed ,old couplings removed and new couplings fixed
OP 5,4,7,9 and CP 3	after rake maintenance done