



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 15/11/2025

Area: WT

Equipment	Job
LC-2B	Old Lotus modem removed.
OT-1 SERIES	Motor side ppm done.
op-3	D-6 motor termination and direction checking done found ok put in circuit.
op-3	panel and motor side ppm done