



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/12/2025

Area: CHP

Equipment	Job
SCR 6 LT	LT VFD ABB drive replaced with SIEMENS drive and tested
CC 54 Gallary	New lighting cable laid and 5nos 50W LED fixtures provided