



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/01/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on co 28	b/w 1 and 2 not running	24dc fuse blown,fuse replaced,but still earth fault,	20:26:00	22:30:00	pending
2	CHP	CC 201	olr acted	reset	14:51:00	14:59:00	
3	CHP	CC 203	PC acted	released	14:45:00	14:55:00	
4	CHP	CC 51	mpd acted	reset	17:20:00	17:30:00	
5	CHP	CC 131	motor tripped	reset	19:40:00	19:50:00	
6	WT	ot 2	d2 tripped in pgf1 fault	reset	19:36:00	19:41:00	