



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/11/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-77	TRIPPED ON OLR	RESET DONE	10:10:00	10:15:00	
2	OHP	CO-26	TRIPPED ON OLR	RESET DONE	11:20:00	11:25:00	
3	OHP	CO-13 (B/D)	OLR ACTED (4TIMES) DUE TO JAMMING	CLEAR THE MATERIAL IN LOCAL MODE RESET DONE AND KEPT IN PLC MODE	10:15:00	11:00:00	
4	OHP	WOBR ON CO-6A	REPORTED ALL DRIVES ARE NOT RUNNING CHECKED AND FOUND CD MAIN POWER ON CONTACT PROBLEM	TEMPORARY BYPASSED THAN CLEARANCE GIVEN BYPASS REMOVED AFTER RECTIFIED	07:30:00	08:30:00	
5	CHP	CC-54	TRIPPED ON OLR (6TIMES)	RESET DONE	11:40:00	13:20:00	
6	CHP	CC-51	MPD TRIP FEEDING CONVEYOR ( 8TIMES)	RESET DONE	07:30:00	13:30:00	
7	CHP	CC-131	TRIPPED ON OLR	RESET DONE	12:40:00	12:50:00	
8	CHP	CC-33 SCR-5	REPORTED B/C STOPPING ON ZSS FOUND ZSS CAGE STUCK UP	OPERATION REQUIREMENT ZSS BYPASSED	07:20:00	07:40:00	INFORMED TO G-SHIFT
9	CHP	CC-39 SCR-2	REPORTED SLEW NOT WORKING FOUND JAMMING AT SLEW AREA	INFORMED TO OPERATION AFTER CLEAR MATERIAL THAN OK	08:10:00	08:25:00	
10	CHP	CC-33 SCR-5	LT NOT TAKING PLACE M-2 MPCB TRIP	RESET DONE THAN OK	09:20:00	09:35:00	
11	CHP	CC-105 SCR-10	LT NOT TAKING PLACE PCRD O/T ACTED	O/T RELEASED AND CABLE PROPER WINDING WAS DONE	09:40:00 10:50:00	10:00:00 11:10:00	
12	WT	OC-1A (B/D)	TRIPPED ON OLR (6 TIMES) DUE TO JAMMING	RESET DONE	06:30:00	12:30:00	
13	WT	OT-1	DRIVE -1 TRIPPED PGF-1 FAULT	RESET DONE	12:00:00	12:05:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	IOSA	BRC ON OC-15A	CT NOT WORKING FOUND DRIVE SIDE (R-7) REVERSE RELAY STUCK UP	RELEASED THAN OK	06:00:00	06:50:00	