



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 03/07/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO26	ALL DRIVES ARE NOT RUNNING E/STOP ACTED	RELEASED	15:00:00	15:30:00	
2	OHP	TBS ON CO 22	R/LUFF OLR ACTED	RESET	16:35:00	16:45:00	
3	OHP	CO 51 (C) DRIVE	MPCB TRIP AND MPCB KNOB BROKEN	MPCB REPLACED	17:05:00	17:30:00	
4	OHP	CO 34	OLR ACTED	RESET	20:30:00	20:40:00	
5	OHP	CO 26	OLR ACTED	RESET	20:50:00	21:00:00	
6	CHP	CC 32 SCR5	LT not taking place, M2 mpcb trips	made it on	17:00:00	17:10:00	
7	CHP	CC 54	OLR ACTED	RESET	18:20:00	18:25:00	
8	CHP	CC 32 SCR 5	no lighting, mpcb trips	made it on	18:45:00	19:00:00	
9	CHP	CC 32 SCR5	b/c not healthy, trips in olr	olr reset in eocr	19:40:00	19:55:00	
10	CHP	CC 35 SCr1	position not showing GVM side, magnetic sensor full covered with coal	sensor cleaned	20:50:00	21:10:00	
11	WT	OT 3	D1 DRIVE TRIPs in pgf1	RESET	18:20:00	18:30:00	