



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 16/01/2026

Area: OHP

Equipment	Job
tbs-7 on co-19	left luff motor failed, replacement is under process.
cbms-4a on co-2a	local trail run is taken and restored in circuit.
co-14	motor and panel side ppm is done
co-2,3,4,sco-1a hmi pop-up	TIS run feedback indication is provided.