



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/10/2025

Area: CHP

Equipment	Job
Misc	JH-7 and tunnel lighting improvement done
CC-55	ppm done
STK-3	shifted from CC-111 bed to repair bay for slew drive modification
SCR-5	LT drive replaced, parameters, control wiring checked and made ok. Failed drive shifted to CM-18
CC-45,48,49	ppm done
CC-108,125,219,222,105,SCR-10	Running inspection done