



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/01/2026

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------------------|------------------------|----------|----------------------|----------------------|---------|
| 1 | OHP | BRC ON CO 28 B/W 2 | ZSS PROBE PROBLEM | BYPASSED | 18:00:00 | 18:15:00 | |
| 2 | OHP | CO 26 | OLR ACTED | RESET | 20:20:00 | 20:30:00 | |
| 3 | CHP | CC 35 | OLR ACTED | RESET | 14:20:00 | 14:30:00 | |
| 4 | CHP | CC 108 | OLR ACTED | RESET | 17:20:00 | 17:25:00 | |
| 5 | CHP | SCR 7 ON CC 37 SLEW | BREAK FAIL ALARM ACTED | RESET | 19:45:00 | 19:55:00 | |
| 6 | CHP | CC 29 | OLR ACTED | RESET | 17:30:00 21:20:00 | 17:40:00 21:30:00 | |
| 7 | CHP | CC 131 | OLR ACTED | RESET | 14:30:00 18:00:00 | 14:35:00 18:05:00 | |
| 8 | CHP | CC 113A | OLR ACTED | RESET | 14:50:00 | 15:00:00 | |
| 9 | CHP | CC 51 | FEEDING CONV OLR ACTED | RESET | 14:30:00 | 21:30:00 | 8 TIMES |
| 10 | IOSA | BRC CT | EMERGENCY ACTED | RELEASED | 15:20:00 | 15:30:00 | |