



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 05/07/2025

Area: IOSA

| Equipment | Job  |
|-----------|--|
| LC-2      | HOUSEKEEPING DONE IN FIRST FLOOR and BATTERY ROOM                                    |
| OC-23A    | MOTOR COVERED WITH BELT PIECE AS RAIN WATER IS FALLING ON MOTOR FROM SHED TOP.       |
| OC-11A    | PPM DONE ON MOTOR AND FIELD DEVICES .  |
| OC-27A    | LIGHTING DEFECTS RECTIFIED IN OC-27A GALLERY AND SUFFICIENT LIGHT FITTINGS ARRANGED. |