



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/01/2026

Incharge(s): Lal Singh,Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR	RESET DONE	00:20:00	00:30:00	
2	OHP	CO-26 WBR	LT NOT WORKING ... PCRD TENSION ACTED	RELEASED	01:05:00	01:20:00	
3	OHP	WBR ON CO -26	BW OLR ACTED	RESET DONE	05:00:00	05:10:00	
4	OHP	BRC ON CO -32	COOLING FAN POWER CONTACTOR 1 PHASE MISSING DUE TO WHICH MPCB TRIPPING	CHANGED AND BYPASSES REMOVED	22:00:00	23:30:00	NO DELAY
5	CHP	CC-51	MPD TRIPPED	RESET DONE	23:55:00	00:00:00	
6	CHP	CC-125	TRIPPED ON OLR	RESET DONE	00:55:00	01:05:00	
7	CHP	CC-35 SCR -3	LT NOT WORKING ALL MOTORS TRIPPED	TRACK COMPLETELY JAM ... RESE AND INFORMED CCR	03:25:00	03:35:00	
8	CHP	CC-34 SCR-4	LT NOT WORKING M1 AMD M2 TRIP DUE TO TRACK JAM	RESET DONE AND INFORMED CCR	04:25:00	04:40:00	