



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 07/12/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-28	CT not moving	MCCB off.Made on.	15:10:00	15:20:00	
2	OHP	CO-25	Tripped	OLR acted.Reset done(2 times)	15:25:00	17:05:00	
3	OHP	RSCO-10A	ZSS acted	ZSS stuck.Made free	15:30:00	17:50:00	
4	OHP	CO-26	Reported tripped	OLR acted.Reset done	20:20:00	20:30:00	
5	OHP	BRC on CO-8A	Reported Pump-1 not healthy	110V control problem rectified.Earth fault found in spider jb.checked and rectified and tested okay	18:30:00	22:00:00	Charge pressure and accumulator pressure problem.Informed to mechanical
6	CHP	CC-35 SCR-3	Reported LT not moving	PCRD switch problem.Wire connected and tested okay	15:20:00	16:30:00	
7	CHP	Cc-125	Reported tripped	OLR acted.Reset done	16:50:00	16:55:00	
8	CHP	Cc 105 SCr 10	LT not Moving	Wrong complaint	21:20:00	21:32:00	
9	CHP	Cc-51	MPD tripped	2 times	17:22:00	17:33:00	
10	CHP	CC 130	PC acted	Reset done	18:35:00	18:40:00	