



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 30/05/2025

Area: OHP

Equipment	Job
VF-8A,9A,10A	IO Bits at 1-141lc3 rack were changed as per new list available over there.
DE-5 fan-2	DMPR is changed , settings were done and local trail run is taken.