



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/07/2025

Shift: A

Incharge(s): Amit Roy,K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|--|----------|----------|--------------------------------|
| 1 | OHP | CO 29 | OLR ACTED | OLR RESET | 06:45:00 | 06:55:00 | |
| 2 | OHP | CO 35 | OLR ACTED | RESET | 08:00:00 | 08:10:00 | |
| 3 | OHP | BRC ON CO-33M | HYDRALIC PUMP NOT RUNNING OIL LOW LEVEL | INFORMED TO OPERATION | 07:15:00 | 07:30:00 | |
| 4 | OHP | BRC ON CO-34 | ALL DRIVES ARE NOT RUNNING CHECKED ACB TRIP | ACB MADE ON THAN OK | 08:04:00 | 09:00:00 | |
| 5 | OHP | CO 87 | REPORTED RED CHECKED PULL CHORD ACTED | INFORMED TO OPERATION | 11:40:00 | 11:50:00 | |
| 6 | OHP | CO-14 | B/S ACTED CHECKED CABLE GOT CUT | B/S BYPASSED IN CJB.Cable joint done and kept in circuit | 11:30:00 | 11:45:00 | CABLE COVER WITH MATERIAL HUMP |
| 7 | OHP | CO-42A | REPORTED BRS NOT RESET | BRS SENSORS CLEAN THAN OK | 11:30:00 | 11:45:00 | |
| 8 | OHP | CO 5 | REPORTED E/STOP NOT RELEASED CHECKED WIRE OPEN CONDITION IN PB POST | E/STOP WIRE CONNECTED THAN OK | 12:00:00 | 12:10:00 | |
| 9 | OHP | CO 14B | OLR ACTED | RESET | 12:35:00 | 12:45:00 | |
| 10 | OHP | BRC ON CO 30 | CT NOT TAKING PLACE DRIVE TRIP | RESET | 12:30:00 | 12:50:00 | |
| 11 | OHP | CR-1A | Stopping on ZSS fault | Jamming found.ZSS probe covered with material. | 12:30:00 | 12:45:00 | informed to operation |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/07/2025

Shift: A

Incharge(s): Amit Roy,K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|---|---|----------------------|----------------------|-----------------------|
| 12 | OHP | RSCO-1A(C/D) | Reported not moving | OLR acted.reset done | 13:40:00 | 13:50:00 | |
| 13 | OHP | DB-1 | Reported C/S acted | High in C/S module found in removed condition.Reconnected and tested okay | 13:30:00 | 13:45:00 | |
| 14 | CHP | CC-18 | OLR ACTED | RESET | 07:30:00 | 07:40:00 | |
| 15 | CHP | CC-117 | OLR ACTED (2TIMES) | RESET | 10:30:00 11:30:00 | 10:40:00 11:40:00 | |
| 16 | CHP | CC 54 | OLR ACTED (3TIMES) | RESET | 07:05:00 | 07:10:00 | 0840,08-50 |
| 17 | CHP | CC-52 | OLR ACTED | RESET | 10:10:00 | 10:20:00 | |
| 18 | CHP | CC-28 TT | POSITION INDICATION NOT SHOWING OON CC-33 GLASS FUSE BLOWN IN I/O RACK | FUSE REPLACED THAN OK | 12:40:00 | 12:50:00 | |
| 19 | CHP | cc-38 s-1 | Slew not taking place | checked and found jamming.after clearing jamming tested okay | 06:50:00 | 07:15:00 | informed to operation |
| 20 | CHP | CC-105 SCR-7 | slew not taking place | Wrong complaint | 07:20:00 | 07:30:00 | informed to operation |
| 21 | CHP | CC-34 SCR-2 | B/C not starting in reclaiming mode | checked and found to be working fine | 08:35:00 | 09:50:00 | Wrong complaint |
| 22 | CHP | CC-40 SCR-3 | Reported LT not taking place | PCRD olr acted. reset done | 09:35:00 | 09:45:00 | |
| 23 | CHP | CC-201 | Reported not healthy | PC acted.Released and tested okay | 10:30:00 | 10:50:00 | |
| 24 | CHP | CC-203 | Reported not healthy | olr acted. reset done | 11:04:00 | 11:13:00 | |
| 25 | CHP | CC-31 S-3 | Reported B/C not working | OLR acted.reset done | 11:50:00 | 12:10:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/07/2025

Shift: A

Incharge(s): Amit Roy, K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|------------------|-------------------------|---------------------------------|----------|----------|---------|
| 26 | CHP | CC-105 scr-10 | Reported signal missing | LT forward done and tested okay | 12:40:00 | 12:50:00 | |
| 27 | CHP | CC-125 | Reported not healthy | OLR acted. reset done | 13:20:00 | 13:25:00 | |