



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 12/01/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-20	R/ LUFF NOT WORKING OLR ACTED	RESET DONE	12:30:00	12:40:00	
2	OHP	CO-67	TRIPPED ON OLR	RESET DONE	07:10:00	07:20:00	
3	OHP	VS-2A	OLR ACTED	RESET DONE	07:50:00	08:00:00	
4	OHP	CO-50	TRIPPED ON OLR	RESET DONE	09:00:00	09:10:00	
5	OHP	BRC ON CO-28	REPORTED B/W-1 NOT RUNNING FOUND GUIDE ROLLER FELL DOWN	INFORMED TO MECHANICAL	10:30:00	10:40:00	
6	OHP	BRC ON CO-28	B/W-2 NOT RUNNING CHAIN FELL DOWN	INFORMED TO MECHANICAL	07:00:00	07:10:00	
7	OHP	WOBR ON CO-26	REPORTED LT NOT TAKING PLACE FOUND PCRD GEAR BOX PROBLEM	PCRD CABLE PROPER LAYING WAS DONE AND INFORMED TO MECH	08:30:00	08:50:00	
8	OHP	CO-12	REPORTED STOPPING ON ZSS CAGE STUCK UP WITH STONE	REMOVED THAN OK	11:15:00	11:25:00	
9	OHP	CO-12	STOPPING ON ZSS	ZSS BYPASSED	13:00:00	13:10:00	TO BE CHECKED IN B SHIFT
10	OHP	CC-40 SCR-2	B/C OLR ACTED	RESET DONE	08:00:00	08:10:00	
11	CHP	CC-117	TRIPPED ON OLR (3TIMES)	RESET DONE	07:00:00 08:35:00 12:45:00	07:05:00 08:40:00 12:50:00	
12	CHP	CC-58	TRIPPED ON OLR (2TIMES)	RESET DONE	08:50:00 09:10:00	08:55:00 09:15:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/01/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-131	TRIPPED ON OLR	RESET DONE	13:10:00	13:15:00	
14	CHP	CC-54	TRIPPED ON OLR (3TIMES)	RESET DONE	11:50:00	12:20:00	
15	CHP	CC-51	OLR ACTED (3TIMES)	RESET DONE	11:00:00	11:30:00	
16	CHP	CC-51	MPD TRIP (5TIMES) FEEDING CONVEYOR STOP	RESET DONE	06:50:00	13:30:00	
17	CHP	CC-39 SCR-6	LT NOT TAKING PLACE DRIVE TRIP 7404 FAULT	RESET DONE	07:50:00	08:00:00	
18	CHP	CC-112 SCR-8	SLEW PUMP NOT RUNNING	PLC POWER RECYCLED THAN OK	08:20:00	08:50:00	
19	CHP	CC-39 SCR-6	LT NOT TAKING PLACE DRIVE FAULT 30002	DRIVE RESET DONE	09:00:00	13:30:00	
20	CHP	CC-125	STOPPING ON ZSS DUE BELT SLOW	INFORMED TO MECH	10:00:00	10:10:00	
21	CHP	CC-34 SCR-1	LT NOT TAKING PLACE DRIVE TRIP DUE TO TRACK JAMMING	RESET DONE AND INFORMED TO OPERATION	13:30:00	13:40:00	
22	WT	OT-1	DRIVE -1 PGF-1 FAULT TRIP	RESET DONE	09:30:00	09:35:00	