



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/12/2025

Area: WT

| Equipment | Job |
|----------------|--|
| OP 10 | Panel side ppm done |
| OP 10 | D3 ,B phase O/G lug replaced and direct termination done@ drive module |
| OP 8 | Panel and Motor side ppm done |
| CP 2 and 3 | After rake, maintenance done |
| OP 2,3,4 and 6 | After rake, maintenance done |
| MIS | M S sheets (3.15), primary painting done both sides 13 nos |