



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 18/06/2025

Area: IOSA

Equipment	Job
OC-15A , OC-17A	BRAKE PANEL GOT RUSTED AND DAMAGED CONDITION . ISOLATED FROM SUPPLY.
OC-11A	ETHERNET CABLE LAYED FROM RMU TO RADIO MODEM
TBS	MAINTENANCE DONE ON RADIO MODEM PANEL AND RADIO MODEM.
OC-11A	MAINTENANCE DONE ON RADIO MODEM PANEL AND RADIO MODEM.
LBDS-2 AIRCOMPRESSOR-1	NOT HEALTHY, CHECKED CIRCUIT , RACKED OUT VCU AND OPERATED IN LOCAL, TEST POSITION.
OC-17A	FIELD DEVICES FEEDBACK CHECKED.
OC-21A,OC-23A AND OC-27A	MAINTENANCE DONE ON VACCUM CONTACTOR UNIT AND TESTED IN RACKED OUT IN LOCAL.
LIGHTING DEFECTS	RECTIFIED LIGHTING DEFECTS IN TBS AND WOBR