



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 11/09/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS-2A	OLR ACTED	RESET DONE	14:35:00	14:50:00	
2	OHP	TBS ON CO-7A	ACB TRIPPED	MADE ON	16:35:00	17:00:00	
3	OHP	VS-2	OLR ACTED	RESET DONE	18:50:00	19:00:00	
4	OHP	BRC ON CO-34	BC OLR ACTED	RESET DONE	19:40:00	20:00:00	
5	OHP	CO-34	OLR ACTED	RESET DONE	18:30:00	18:35:00	
6	CHP	cc-51	MPD TRIP	RESET DONE (7 TIMES)	18:17:00	21:45:00	
7	CHP	CC-131	TRIPPED ON OLR	RESET DONE	21:25:00	21:27:00	
8	CHP	cc-36 SCR-1	POSITION SENSOR PROBLEM	BYPASSED	16:30:00	17:00:00	
9	CHP	CC-31 SCR-4	TRIPPING IN CHARGE PRESSURE	INFORMED MECH	18:20:00	19:00:00	
10	CHP	CC-112 SCR-8	LUFF NOT WORKING	OIL LEVEL LOW	19:00:00	19:20:00	
11	CHP	CC-37 SCR-7	SLEW NOT WORKING	OIL COOLER TRIP ... RESET	20:30:00	21:00:00	
12	WT	CO-3	TRIPPED ON OLR	RESET DONE	19:20:00 20:15:00	19:25:00 20:25:00	