



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/01/2026

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------------|-----------------------------|------------|----------------------------------|----------------------------------|----------|
| 1 | OHP | CO 16 | OLR ACTED | RESET | 03:10:00 03:35:00 05:00:00 | 03:15:00 03:40:00 05:10:00 | |
| 2 | OHP | CO 33M LT | PCRD O/T ACTED | RELEASED | 03:00:00 | 03:10:00 | |
| 3 | OHP | CO 33 M | OLR ACTED | RESET | 00:00:00 | 00:10:00 | |
| 4 | OHP | CO 26 | OLR ACTED | RESET | 02:10:00 02:45:00 | 02:20:00 02:50:00 | |
| 5 | CHP | SCR 1 ON CC 34 | B/C POSITION SWITCH PROBLEM | BYPASSED | 04:20:00 | 04:35:00 | |
| 6 | CHP | CC 51 | FEEDING CONV ACTED | RESET | 22:30:00 | 05:45:00 | 16 TIMES |
| 7 | CHP | CC 51 | OLR ACTED | RESET | 00:00:00 | 04:30:00 | 3 TIMES |
| 8 | CHP | CC 131 | OLR ACTED | RESET | 23:45:00 | 05:45:00 | 7 TIMES |
| 9 | CHP | CC 29 | OLR ACTED DUE TO JAMMING | RESET | 00:30:00 | 05:30:00 | 5 TIMES |
| 10 | WT | OP2 | D5 OLR ACTED | MADE IT ON | 22:20:00 | 22:35:00 | 3 TIMES |