



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------------|---|-------------------------|----------|----------|---------------|
| 1 | OHP | BRC on CO 33M | LT not working,PCRD OT acted | released | 08:30:00 | 08:40:00 | guide problem |
| 2 | OHP | BRC on CO 28 | all drive not working,acb tripped | ACB made on | 11:55:00 | 12:05:00 | |
| 3 | OHP | wobr on co 29 | b/c not running | operator cabin reset | 10:55:00 | 11:00:00 | |
| 4 | OHP | 1-28 HVMCC 4 | oc 9a,11a,3a no power,l/c 2 tripped in LBDS 8 | made it on by CRP | 13:40:00 | 14:05:00 | |
| 5 | CHP | CC 28(B) | olr acted | reset | 10:40:00 | 10:47:00 | |
| 6 | CHP | CC 117 | olr acted | reset | 08:35:00 | 08:50:00 | |
| 7 | CHP | CC 113A | olr acted | reset | 12:22:00 | 12:25:00 | |
| 8 | WT | CO 4(C) | olr acted | reset | 11:20:00 | 11:25:00 | |
| 9 | IOSA | LBDS 2 6.6 KV hvmcc 5 | i/c 1 tripped | made it on by CRP panel | 06:40:00 | 06:50:00 | |