



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/11/2025

Area: CHP

Equipment	Job
CC 39,42,44,125	Motor Vibration readings noted
VFD panels	Shifted to LBDS 1@8
CC 47/48 slope	Lighting improved
SCR 2	Shifted from repair bay to CC 39
SCR 2	MCC roof and Transformer roof sheets welding done
CC 201,202,203,219,222,223	PPM was done