



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/09/2025

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment            | Problem                              | Action                             | From                 | To                   | Remarks |
|-------|------|----------------------|--------------------------------------|------------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO 11 CARRIAGE DRIVE | MPCB TRIPPED                         | MADE IT ON                         | 04:00:00<br>23:00:00 | 04:15:00<br>23:10:00 |         |
| 2     | OHP  | TT4 LT               | MPCB TRIPPED                         | MADE IT ON                         | 03:30:00             | 03:45:00             |         |
| 3     | OHP  | CO 9                 | OLR ACTED                            | RESET                              | 22:05:00             | 22:15:00             |         |
| 4     | OHP  | WBR ON CO 26         | SLEW DRIPPED                         | RESET                              | 22:40:00             | 22:55:00             |         |
| 5     | CHP  | SCR 7 ON CC 37       | PCRD OLD CABLE JOINT GOT OPENED      | INFORMED TO DNW                    | 00:00:00             | 06:00:00             |         |
| 6     | CHP  | SCR 8 ON CC 112 LUFF | OIL LEVEL LOW                        | AFTER FILLING OIL THEN OK          | 02:45:00             | 03:00:00             |         |
| 7     | CHP  | SCR 5 ON CC 32 LT    | O/T ACTED DUE TO CABLE ZIG ZAG       | RELEASED AND PROPERLY WINDING DONE | 23:40:00             | 00:15:00             |         |
| 8     | CHP  | CC 31                | OLR ACTED                            | RESET                              | 01:50:00             | 02:00:00             |         |
| 9     | CHP  | SCR 1 ON CC 36       | B/W OLR ACTED                        | RESET                              | 02:00:00             | 02:20:00             |         |
| 10    | CHP  | LC 19                | FEEDER 1 TRIPPED                     | MADE IT ON                         | 22:50:00             | 23:00:00             |         |
| 11    | CHP  | CC 51                | FEEDING CONVEYOR OLR TRIPPED 8 TIMES | RESET                              | 00:00:00             | 06:00:00             |         |