



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/01/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	Reported tripped	OLR acted.Reset done	22:45:00	22:55:00	
2	OHP	WOBR on CO-25	Reported slewing not taking place	Drive tripped.Reset done	22:30:00	22:40:00	
3	OHP	WOBR on CO-25	Reported LT not taking place	LT brake adjustment done and control problem rectified.	02:50:00	03:20:00	
4	CHP	Cc-51	MPD tripped	Feeding conveyor stopped.Reset done(4 times)	03:10:00	04:15:00	
5	CHP	Cc-131	Reported tripped	OLR acted.Reset done(3 times)	01:20:00	02:15:00	
6	WT	OT-2	Reported tripped	Drive-2 tripped on PGEF-1 fault.Reset done	02:50:00	02:55:00	
7	IOSA	TBS	Reported LT not taking place	Boom limit striker bent.Bypassed and joystick found stuck.Made free and tested okay	01:00:00	01:30:00	Striker to be welded.