



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on CO 6A	pending complaint,both 12 slot extendable rack having problem ,lower and upper house	rack replaced	22:00:00	03:10:00	
2	OHP	co 29	OLR acted	reset	23:00:00	23:08:00	2 times
3	OHP	brc on co 30	bc not running,olr acted	reset	22:35:00	22:50:00	
4	OHP	tbs on co 21	LT not working,Brake problem	informed operation	22:30:00	22:45:00	
5	CHP	cc 35 scr3	LT not working,drive tripped	reset	22:40:00	22:55:00	
6	CHP	cc 125	olr acted	reset	00:15:00	00:25:00	
7	CHP	CC 34 scr 2	b/c not running,zss sensor not working	bypassed in i/o rack	01:00:00	01:15:00	informed A shift to replaced
8	CHP	CC 26 A	mpcb tripped of flap gate	made it on	22:30:00	22:40:00	
9	CHP	CC 26 signal to cc 38	signal missed,loose connection in tbs	tightened	23:00:00	23:10:00	
10	WT	OC 1A(B)	OLR acted	reset	02:00:00	02:10:00	
11	WT	OT1	wagon over traveled O/L side and tippler rotated 20 degree,sensor acted and RLS not high	sensor and RLS bypass and kept in ckt after wagon proper placement in tippler	01:00:00	01:10:00	