



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/11/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|---|----------------------------------|----------------------|----------------------|---------|
| 1 | OHP | CO-29 | OLR ACTED | RESET DONE | 07:50:00 | 08:00:00 | |
| 2 | OHP | CO-10A | OLR ACTED | RESET DONE | 06:40:00 | 06:50:00 | |
| 3 | OHP | BRC ON CO-33-M | CT NOT TAKING PLACE FOUND CONTROL MCB TRIP | CONTROL MCB MADE ON | 07:50:00 | 08:10:00 | |
| 4 | OHP | CO-26 | TRIPPED ON OLR | RESET DONE | 10:30:00 | 10:40:00 | |
| 5 | OHP | CO-33M | OLR ACTED | RESET DONE | 11:40:00 | 11:50:00 | |
| 6 | CHP | CC-51 | MPD TRIP (2TIMES) FEEDING CONVEYOR STOP | RESET DONE | 09:00:00 10:15:00 | 09:10:00 10:20:00 | |
| 7 | CHP | CC-131 | OLR ACTED | RESET DONE | 12:55:00 | 13:00:00 | |
| 8 | CHP | CC-125 | OLR ACTED (2TIMES) | RESET DONE | 08:36:00 10:10:00 | 08:40:00 10:15:00 | |
| 9 | CHP | CC-201 | TRIPPED ON OLR (2TIMES) | RESET DONE | 09:20:00 09:30:00 | 09:25:00 09:45:00 | |
| 10 | CHP | CC-203 | OLR ACTED (2TIMES) | RESET DONE | 09:20:00 10:30:00 | 09:30:00 10:40:00 | |
| 11 | CHP | CC-33 SCR-5 | REPORTED B/C NOT RUNNING FOUND SIGNAL PROBLEM | LT MOVE FWD THAN OK | 10:45:00 | 11:30:00 | |
| 12 | IOSA | OC-7B | REPORTED FAIL TO START | CONTROL SUPPLY RE-CYCLED THAN OK | 13:15:00 | 13:25:00 | |