



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/01/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 34	OLR ACTED	RESET	19:20:00 19:35:00	19:25:00 19:40:00	
2	OHP	CO 25	OLR ACTED	RESET	20:35:00	20:45:00	
3	OHP	TBS ON CO 20 LT	MPCB TRIP	MADE IT ON	16:45:00	17:00:00	
4	OHP	DAYBINS , RSCO 10A RED	INCOMER 1 TRIPPED IN NEW LC3 DUE TO UNDER VOLTAGE FAULT	RESET MADE IT ON	16:55:00	17:05:00	
5	CHP	CC 51	FEEDING CONV MPD ACTED	RESET	15:00:00	18:30:00	5 TIMES
6	CHP	CC 52	FEEDING CONV MPD ACTED	RESET	15:00:00	21:50:00	5 TIMES
7	CHP	CC 54	OLR ACTED	RESET	15:05:00	15:15:00	
8	CHP	CC 132	OLR ACTED	RESET	16:05:00 21:45:00	16:15:00 21:55:00	
9	WT	OT2	DRIVE 2 TRIPPED ON PGF1 FAULT	RESET	16:15:00	16:20:00	
10	WT	OT4	DRIVE 1 TRIPPED PGF4 FAULT	RESET	16:55:00	17:00:00	
11	WT	OP5	DRIVE 5 OLR ACTED DURING COUPLING TIME	RESET	14:20:00	14:30:00	
12	WT	OT2	DRIVE 2 TRIPPED ON PGF4 FAULT	RESET	21:20:00	21:30:00	