



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/05/2025

Area: WT

| Equipment | Job   |
|-----------|---|
| AF 3(O)   | local Inch start push button replaced                                       |
| OT 5      | out haul side lighting ,circuit problem rectified and kept in timer circuit |
|           | lighting problem rectified 3 nos 150W SV and 1no 35W LED replaced           |
| CP 4      |   |
| OP 3      | D4 one lug found cut in motor TB ,replaced and 1no top jumper replaced      |
|           | after rake maintenance done   |

CO 5,6 &7 tunnel

OP 2,3,4,5,6,7 &10