



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/01/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	SCR 6 ON CC 39	LT DRIVE TRIPPED	RESET	09:55:00	10:10:00	
2	CHP	cc 51	FEEDING CONV MPD OLR ACTED	RESET	09:00:00	14:00:00	17 TIMES
3	CHP	CC 51	OLR ACTED	RESET	12:00:00	12:10:00	
4	CHP	CC 114	OLR ACTED	RESET	07:50:00	08:00:00	
5	CHP	VS3	OLR ACTED	RESET	12:30:00	12:40:00	
6	CHP	RG3	TRIPPED DUE TO ROTOR JAMMING	RESET	12:55:00	13:10:00	
7	WT	CO 2	ZSS PROBE DAMAGED	REPLACED	09:00:00	09:30:00	
8	WT	OT2	D2 TRIPPED ON PGF1 FAULT	RESET	09:55:00 10:05:00	10:00:00 10:10:00	